

SDoC Identification Number¹: VYN FBIP2P2DNC CIRCULAR FLOOR BOX: 30/03/2023

Issuer details

Name ² (of New Zealand manufacturer or importer): VYNCO INDUSTRIES (NZ) LTD.	Contact Address: 388-396 TUAM STREET. PHILIPSTOWN CHRISTCHURCH 8149 NEW ZEALAND www.vynco.co.nz
Telephone: +64 3 379 9283	
New Zealand Company No. (if applicable): CH506239 03/07/91	
Email Address: sales@vynco.co.nz	

Medium Risk Article – Details³ (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

FBIP2PDNC CIRCULAR FLOOR BOX WITH TWO 250V 10A AUTO SWITCHED PANEL SOCKETS.

The Medium Risk Article listed above, fully complies:

With cited standard(s), as listed⁴:	
Standard number and issue year: AS/NZS 3112	Standard number and issue year: BSEN 60529
Edition / Amendment status: 2011 +A1+A2	Edition / Amendment status: 1992+A1+A2:2003
Standard title: APPROVAL AND TEST SPECIFICATIONS – PLUGS AND SOCKET OUTLETS	Standard title: DEGREES OF PROTECTION PROVIDED BY ENCLOSURES (IP CODE).
AS/NZS ZZ modified Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	AS/NZS ZZ modified Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input checked="" type="checkbox"/>
OR Complies with the Conformity Cooperation Agreement (CCA) ⁵ Yes <input type="checkbox"/> No <input type="checkbox"/> EESS Equipment # _____	


Names and addresses of any Evaluating/Testing/Certification organisation or body used

Name(s): NSW FAIR TRADING	Address(es): ENERGY & UTILITIES UNIT – NSW FAIR TRADING PO BOX 972 PARRAMATTA NSW 2124 AUSTRALIA
Name(s): INTERTEK TESTING SERVICES	Address(es): BUILDING NO 86, 1198 QINZHOU ROAR NORTH. SHANGHAI 200233 CHINA.

Reference to relevant test reports/certification and the issue date that show how compliance is achieved

Supporting document(s) used, to show how compliance with the declared standard(s) is achieved or CCA certification:	Report Certification or Document reference N°(s):	Issue dates(s):
AUSTRALIAN CERTIFICATE OF APPROVAL TO AS/NZS3112: FOR SOCKET OUTLET – RSSDP10 250V a.c. 10A PANEL MOUNT SOCKET.	NSW26768	02/07/2019
IP66 TEST REPORT TO BSEN 60529 – FBIP2P2DNC	160600636SHA-001	28/06/2016
Reference to any management quality system involved: _____		
Additional information ⁷ : _____		

Declaration (signed for and on behalf of):-

Name and position as authorised by the issuer ⁸ : JOHN VALE - CEO	Signature: 
Issuer Identification (as affixed to the article): RSDP10 FOR SOCKET AND FBIP2P2DNC FOR CIRCULAR FLOOR BOX HOUSING.	Date: 30/03/2023