

SDoC Identification Number¹: VYN HOT WATER ISOLATORS:14/07/2021

Issuer details

Name ² (of New Zealand manufacturer or importer): VYNCO INDUSTRIES (NZ) LTD.	Contact Address: 388-396 TUAM STREET. PHILIPSTOWN CHRISTCHURCH 8149 NEW ZEALAND www.vynco.co.nz
Telephone: +64 3 379 9283	
New Zealand Company No. (if applicable): CH506239 03/07/91	
Email Address: sales@vynco.co.nz	

Medium Risk Article – Details³ (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

HWIKS - HOT WATER ISOLATOR KIT STRAIGHT
 HWIKA – HOT WATER ISOLATOR KIT ANGLED
 HWIPCU – HOT WATER ISOLATOR PERMANENT CONNECTION UNIT.

The Medium Risk Article listed above, fully complies:


With cited standard(s), as listed⁴:	
Standard number and issue year: AS/NZS 3133	Standard number and issue year: AS/NZS 3100
Edition / Amendment status: 2013 INCL A1 + A2	Edition / Amendment status: 2017 INCL A1 – A3
Standard title: APPROVAL AND TEST SPECIFICATION – AIR BREAK SWITCHES	Standard title: APPROVAL AND TEST SPECIFICATION – GENERAL REQUIREMENTS FOR ELECTRICAL EQUIPMENT.
AS/NZS ZZ modified Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A <input type="checkbox"/>	AS/NZS ZZ modified Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A <input type="checkbox"/>
OR Complies with the Conformity Cooperation Agreement (CCA) ⁵ Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
OR is registered on the EESS database & the declarer is registered as the responsible/affiliated supplier ⁶ Yes <input type="checkbox"/> No <input type="checkbox"/> EESS Equipment # _____	

Names and addresses of any Evaluating/Testing/Certification organisation or body used

Name(s): CENTRAL POINT TESTING AND TECHNOLOGY CO LTD	Address(es): NO 11, WU SONG ROAD, DONGCHENG DISTRICT, DINGGUAN GUANGDONG PROVINCE CHINA 523117
Name(s): SAA APPROVAL PTY LTD	Address(es): UNIT 5, 20 RIVERGATE PLACE, MURARRIE QUEENSLAND 4172, AUSTRALIA.

Supporting document(s) used, to show how compliance with the declared standard(s) is achieved or CCA certification:	Report Certification or Document reference N°(s):	Issue dates(s):
CPC TEST REPORT TO AS/NZS 3133 FOR HWSIK HOT WATER ISOLATOR AS AN ISOLATING SWITCH	90189-21-70-21-PP002	21 JUNE 2021
SAA CERTIFICATE OF APPROVAL FOR HWIKS SAA CERTIFICATE OF APPROVAL FOR CABLE	SAA-210869-EA SAA-173190-EA	13 JULY 2021 2 JANUARY 2018
Additional information ⁷ : _____		

Declaration (signed for and on behalf of):-

Name and position as authorised by the issuer ⁸ : JOHN VALE - CEO	Signature: 
Issuer Identification (as affixed to the article): RCM AND HWIKS OR HWIKA OR HWIPCU.	Date: 14/07/2021