

VYNCO

WPS120C INSTALLATION

INSTALLER NOTES

1. Use template in carton to mark and drill mounting holes.
2. Please ensure all cover screws are tightened to at least 1Nm, if less IP rating may be void.
3. Insert caps provided to cover screws.
4. To maintain IP66 rating, all conduit entries (used or unused) and fixing points must be sealed using suitable sealant.

LOCKING FACILITY

8mm lockout available in the off position.

